

Arlington Elementary Action Plan: Lead in Drinking Water

School Information

School Name(s): Arlington

School District: Spokane Public Schools

County: Spokane

Sampling and Testing Information

School Name	Sampling Date	Date Test Results Received	Sampling and Testing Provider
Arlington	5/2/2024	5/31/2024	<input checked="" type="checkbox"/> DOH (for sampling and testing) <input type="checkbox"/> Other: [Click here to enter sampling and testing provider name(s)]

Testing Requirements

[RCW 28A.210.410](#) and [RCW 43.70.830](#) require all drinking water outlets in public schools built, or with all plumbing replaced, before 2016 be tested for lead at least once between July 1, 2014, and June 30, 2026. Retesting shall occur at least once every five years thereafter. Drinking water sampling and testing must be done in partnership with DOH or contracted through an [accredited lab](#).

Action Plan Requirements

If test results reveal elevated lead levels above 5 parts per billion (ppb) at any outlet used for drinking or cooking, an action plan must be developed. If your school has an existing action plan, you have the option of updating the existing plan to meet the following requirements instead of creating a new one.

Per [RCW 28A.210.410](#), a school's action plan must meet the following requirements:

- The action plan shall be developed in consultation with DOH or your local health jurisdiction and in accordance with [DOH's technical guidance](#).
- Consult with the Office of the Superintendent of Public Instruction (OSPI) when seeking funding for remediation activities. The OSPI [Lead in Water Remediation Grant](#) is a potential source of funding.

- Before the action plan is officially adopted, it must be shared publicly with opportunity for public comment.
- For testing that occurred after July 25, 2021, the deadline for adopting the action plan is six months after receiving elevated lead test results.
- The action plan must include:
 - 1) **Mitigation measures** implemented since receiving elevated lead test results.
 - 2) A schedule of **remediation activities** that adhere to the [technical guidance](#). The schedule may be based on the availability of state or federal funding for remediation activities.
 - 3) A plan for **post-remediation sampling and testing** to confirm remediation activities have reduced lead concentrations at drinking water outlets to 5 or fewer ppb.

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

Action Plan

Mitigation Measures

Mitigation measures are immediate (temporary or permanent) actions, such as shutting off an outlet or marking as “hand wash only,” to stop access to drinking water with elevated lead concentrations. Outlets with lead concentrations exceeding 15 ppb must be shut off immediately upon receiving test results in accordance with the [technical guidance](#).

Arlington Elementary has identified 24 drinking water outlets with elevated lead levels requiring mitigation.

Mitigation measures have been implemented as Temporary

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure (Indicate temporary or permanent)	Date Implemented
1)	5/2/2024	388330	Arlington Portable	Sink	50	Labeled “hand washing only” <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	6/3/2024
2)	5/2/2024	378235	Arlington Main	sink	41	Labeled “hand washing only” <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	6/3/2024
3)	5/2/2024	378681	Arlington Main	sink	41	Labeled “hand washing only” <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	6/3/2024
4)	5/2/2024	378232	Arlington Main	sink	17	Labeled “hand washing only” <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	6/3/2024
5)	5/2/2024	378727	Arlington Main	sink	17	Labeled “hand washing only” Temporary	6/3/2024
6)	5/2/2024	378689	Arlington Main	sink	16	Labeled “hand washing only” Temporary	6/3/2024
7)	5/2/2024	388302	Arlington Main	sink	16	Labeled “hand washing only” Temporary	6/3/2024

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

8)	5/2/2024	378693	Arlington Main	sink	15	Labeled "hand washing only" Temporary	6/3/2024
9)	5/2/2024	378729	Arlington Main	sink	14	Labeled "hand washing only" Temporary	6/3/2024
10)	5/2/20204	388306	Arlington Main	sink	14	Labeled "hand washing only" Temporary	6/3/2024
11)	5/2/2024	388326	Arlington Portable	sink	14	Labeled "hand washing only" Temporary	6/3/2024
12)	5/2/2024	378724	Arlington Main	sink	13	Labeled "hand washing only" Temporary	6/3/2024
13)	5/2/2024	378233	Arlington Main	sink	12	Labeled "hand washing only" Temporary	6/3/2024
14)	5/2/2024	388332	Arlington Main	sink	11	Labeled "hand washing only" Temporary	6/3/2024
15)	5/2/2024	378697	Arlington Main	Sink	10	Labeled "hand washing only" Temporary	6/3/2024
16)	5/2/2024	378236	Arlington Main	Sink	8	Labeled "hand washing only" Temporary	6/3/2024
17)	5/2/2024	378732	Arlington Main	Sink	8	Labeled "hand washing only" Temporary	6/3/2024
18)	5/2/2024	378192	Arlington Main	Sink	7	Labeled "hand washing only" Temporary	6/3/2024
19)	5/2/2024	378687	Arlington Main	sink	7	Labeled "hand washing only" Temporary	6/3/2024
20)	5/2/2024	378734	Arlington Main	sink	7	Labeled "hand washing only" Temporary	6/3/2024
21)	5/2/2024	378186	Arlington Main	sink	6	Labeled "hand washing only" Temporary	6/3/2024
22)	5/2/2024	378188	Arlington	Sink	6	Labeled "hand washing only"	6/3/2024

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

			Main			Temporary	
23)	5/2/2024	378196	Arlington Main	sink	6	Labeled "hand washing only" Temporary	6/3/2024
24)	5/2/2024	378695	Arlington Main	Sink	6	Labeled "hand washing only" Temporary	6/3/2024

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

Remediation Schedule

Remediation activities are short-term or permanent control measures to reduce lead concentrations in drinking water to 5 ppb or less. Per RCW 28A.210.410, outlets that have elevated lead levels (above 5 ppb) must be identified, remediated (if not permanently mitigated), and retested. Refer to the [technical guidance](#) for remediation options.

Arlington Elementary has identified 24 drinking water outlets with elevated lead levels requiring remediation. (Outlets listed in the previous table with **temporary** mitigation measures are repeated in the table below.)

Remediation activities have been or will be implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Remediation Activity	Planned or Completed Implementation Date
1)	5/2/2024	388330	Arlington Portable	Tap	50	Shut off water/change fixture	ASAP
2)	5/2/2024	378235	Arlington Main	Tap	41	Shut off water/change fixture	ASAP
3)	5/2/2024	378681	Arlington Main	Tap	41	Shut off water/change fixture	ASAP
4)	5/2/2024	378232	Arlington Main	Tap	17	Shut off water/change fixture	ASAP
5)	5/2/2024	378727	Arlington Main	Tap	17	Shut off water/change fixture	ASAP
6)	5/2/2024	388302	Arlington Main	Tap	16	Shut off water/change fixture	ASAP
7)	5/2/2024	378689	Arlington Main	Tap	16	Shut off water/change fixture	ASAP
8)	5/2/2024	378693	Arlington/Main	Tap	15	Shut off water/change fixture	ASAP
9)	5/2/2024	378729	Arlington	Tap	14	Shut off water/change fixture	ASAP

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

			Main				
10)	5/2/2024	388306	Arlington Main	Tap	14	Shut off water/change fixture	ASAP
11)	5/2/2024	388326	Arlington Portable	Tap	14	Shut off water/change fixture	ASAP
12)	5/2/2024	378724	Arlington Main	Tap	13	Shut off water/change fixture	ASAP
13)	5/2/2024	378233	Arlington Main	Tap	12	Shut off water/change fixture	ASAP
14)	5/2/2024	388332	Arlington Portable	Fountain	11	Shut off water/change fixture	ASAP
15)	5/2/2024	378697	Arlington Main	Tap	10	Shut off water/change fixture	ASAP
16)	5/2/2024	378236	Arlington Main	Tap	8	Shut off water/change fixture	ASAP
17)	5/2/2024	378732	Arlington Main	Tap	8	Shut off water/change fixture	ASAP
18)	5/2/2024	378192	Arlington Main	Tap	7	Shut off water/change fixture	ASAP
19)	5/2/2024	378687	Arlington Main	Tap	7	Shut off water/change fixture	ASAP
20)	5/2/2024	378734	Arlington Main	Tap	7	Shut off water/change fixture	ASAP
21)	5/2/2024	378186	Arlington Main	Tap	6	Shut off water/change fixture	ASAP
22)	5/2/2024	378188	Arlington Main	Tap	6	Shut off water/change fixture	ASAP
23)	5/2/2024	378196	Arlington Main	Tap	6	Shut off water/change fixture	ASAP

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

24)	5/2/2024	378695	Arlington Main	Tap	6	Shut off water/change fixture	ASAP
-----	----------	--------	-------------------	-----	---	-------------------------------	------

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

Contact Information

The following person(s) is the main point of contact for more information related to this action plan.

Spokane Public Schools

Email: rebeccado@spokaneschools.org

Phone: 509-354-7771

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

*****This page is for DOH’s publication purposes only.*****

*****It can be deleted from your action plan.*****

After deleting this page, save as PDF for distribution. Please reach out to leadfreekids@doh.wa.gov with questions and feedback related to this action plan template.



DOH 334-489 March 2023

To request this document in another format, call 1-800-525-0127. Deaf or hard of hearing customers, please call 711 (Washington Relay) or email civil.rights@doh.wa.gov.

**Double click in this area to access footer, then: [Click here to enter school or district name]