

Lead in School Drinking Water Report

Arlington Elementary School



Date(s) collected: 2024-05-02

Date(s) analyzed: 2024-05-20, 2024-05-21

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
388330	Portable A	Sink	Room A-102	1 of 1	Tap	center	50
378235	Main Building	Sink	Kitchen	3 of 4. Island sink	Tap	center	41
378681	Main Building	Sink	Music Room	1 of 1	Tap	center	41
378232	Main Building	Sink - Multi-Compartment	Kitchen	1 of 4	Tap	left	17
378727	Main Building	Sink	Room 123	1 of 1	Tap	left	17
378689	Main Building	Sink	Room 207	1 of 1	Tap	left	16
388302	Main Building	Sink	Room 219	1 of 1	Tap	left	16
378693	Main Building	Sink	Room 209	1 of 1	Tap	left	15

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
378729	Main Building	Sink	Room 121	1 of 1	Tap	left	14
388306	Main Building	Sink	Room 145	1 of 2	Tap	center	14
388326	Portable A	Sink	Room A-101	1 of 1	Tap	center	14
378724	Main Building	Sink	Room 127	1 of 1	Tap	left	13
378233	Main Building	Sink - Multi-Compartment	Kitchen	1 of 4	Tap	right	12
388332	Portable A	Sink	Room A-102	1 of 1	Water Fountain	right	11
378697	Main Building	Sink	Room 215	1 of 1	Tap	left	10
378236	Main Building	Sink - Multi-Compartment	Kitchen	4 of 4	Tap	center	8
378732	Main Building	Sink	Room 119	1 of 1	Tap	left	8
378192	Main Building	Sink	Room 105	1 of 1	Tap	left	7
378687	Main Building	Sink	Room 205	1 of 1	Tap	left	7
378734	Main Building	Sink	Room 117	1 of 1	Tap	left	7
378186	Main Building	Sink	Room 111	1 of 1	Tap	left	6
378188	Main Building	Sink	Room 109	1 of 1	Tap	left	6
378196	Main Building	Sink	Room 101	1 of 1	Tap	left	6
378695	Main Building	Sink	Room 211	1 of 1	Tap	left	6
378194	Main Building	Sink	Room 103	1 of 1	Tap	left	5
378682	Main Building	Sink	Music Room	1 of 1	Water Fountain	right	5

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
378683	Main Building	Sink	Room 201	1 of 1	Tap	left	5
378699	Main Building	Sink	Room 217	1 of 1	Tap	left	5
378187	Main Building	Sink	Room 111	1 of 1	Water Fountain	right	4
378720	Main Building	Sink	Room 133	1 of 1	Tap	left	4
378722	Main Building	Sink	Room 129	1 of 1	Tap	left	4
378723	Main Building	Sink	Room 129	1 of 1	Water Fountain	right	4
378725	Main Building	Sink	Room 127	1 of 1	Water Fountain	right	4
378728	Main Building	Sink	Room 123	1 of 1	Water Fountain	right	4
378730	Main Building	Sink	Room 121	1 of 1	Water Fountain	right	4
378737	Main Building	Sink	Room 115	1 of 1	Water Fountain	right	4
378738	Main Building	Sink	Room 113	1 of 1	Tap	left	4
388308	Main Building	Sink - Multi-Compartment	Room 145	2 of 2	Tap	center	4
388328	Portable A	Sink	A-101	1 of 1	Water Fountain	right	4
378190	Main Building	Sink	Room 107	1 of 1	Tap	left	3
378195	Main Building	Sink	Room 103	1 of 1	Water Fountain	right	3
378197	Main Building	Sink	Room 101	1 of 1	Water Fountain	right	3
378198	Main Building	Sink	Nurses Office	1 of 2	Tap	center	3
378237	Main Building	Fountain	Gym	1 of 1	Water Fountain	right	3

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
378684	Main Building	Sink	Room 201	1 of 1	Water Fountain	right	3
378685	Main Building	Sink	Room 203	1 of 1	Tap	left	3
378691	Main Building	Sink	Room 207	1 of 1	Water Fountain	right	3
378692	Main Building	Fountain	Across From Room 209	1 of 1	Water Fountain	right	3
378694	Main Building	Sink	Room 209	1 of 1	Water Fountain	right	3
378721	Main Building	Sink	Room 133	1 of 1	Water Fountain	right	3
378726	Main Building	Fountain	Across From Room 123 In Between Restrooms	1 of 1	Water Fountain	right	3
378735	Main Building	Sink	Room 117	1 of 1	Water Fountain	right	3
378736	Main Building	Sink	Room 115	1 of 1	Tap	left	3
378739	Main Building	Sink	Room 113	1 of 1	Water Fountain	right	3
378189	Main Building	Sink	Room 109	1 of 1	Water Fountain	right	2
378191	Main Building	Sink	Room 107	1 of 1	Water Fountain	right	2
378193	Main Building	Sink	Room 105	1 of 1	Water Fountain	right	2
378234	Main Building	Sink	Kitchen	2 of 4	Sprayer	center	2
378680	Main Building	Fountain	In Between Restrooms 154b And 154a	1 of 1	Water Fountain	right	2
378688	Main	Sink	Room 205	1 of 1	Water	right	2

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building				Fountain		
378733	Main Building	Sink	Room 119	1 of 1	Water Fountain	right	2
388304	Main Building	Sink	Room 219	1 of 1	Water Fountain	right	2
378686	Main Building	Sink	Room 203	1 of 1	Water Fountain	right	1
388300	Main Building	Sink	Room 217	1 of 1	Water Fountain	right	1
378199	Main Building	Ice Machine	Nurses Office	2 of 2	Other	other	<1
378238	Main Building	Fountain with Bottle Filler	Next To Room 134a	1 of 1	Water Bottle Filler	center	<1
378239	Main Building	Fountain with Bottle Filler	Next To Room 134a	1 of 1	Water Fountain	right	<1
378696	Main Building	Sink	Room 211	1 of 1	Water Fountain	right	<1
378698	Main Building	Sink	Room 215	1 of 1	Water Fountain	right	<1
378731	Main Building	Sink	Staff Room	1 of 1	Tap	center	<1
388310	Portable	Sink	Room C-101	1 of 1	Tap	center	<1
388312	Portable C	Sink	Room C-101	1 of 1	Water Fountain	left	<1
388314	Portable C	Sink	C-102	1 of 1	Tap	center	<1
388316	Portable C	Sink	Room C-102	1 of 1	Water Fountain	right	<1
388318	Portable B	Sink	Room B-102	1 of 1	Tap	center	<1
388320	Portable B	Sink	B-102	1 of 1	Water Fountain	right	<1
388322	Portable B	Sink	Room B-101	1 of 1	Tap	center	<1
388324	Portable	Sink	Room B-	1 of 1	Water	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	B		101		Fountain		

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**