

Balboa Elementary Action Plan: Lead in Drinking Water

School Information

School Name(s): Balboa Elementary

School District: Spokane Public Schools

County: Spokane

Sampling and Testing Information

School Name	Sampling Date	Date Test Results Received	Sampling and Testing Provider
Balboa	4/18/2024	35	<input checked="" type="checkbox"/> DOH (for sampling and testing) <input type="checkbox"/> Other: [Click here to enter sampling and testing provider name(s)]
Balboa	4/18/2024	19	DOH
Balboa	4/18/2024	14	DOH
Balboa	4/18/2024	10	DOH
Balboa	4/18/2024	10	DOH
Balboa	4/18/2024	9	DOH
Balboa	4/18/2024	9	DOH
Balboa	4/18/2024	8	DOH
Balboa	4/18/2024	8	DOH
Balboa	4/18/2024	6	DOH
Balboa	4/18/2024	6	DOH

Testing Requirements

[RCW 28A.210.410](#) and [RCW 43.70.830](#) require all drinking water outlets in public schools built, or with all plumbing replaced, before 2016 be tested for lead at least once between July 1, 2014, and June 30, 2026. Retesting shall occur at least once every five years thereafter. Drinking water sampling and testing must be done in partnership with DOH or contracted through an [accredited lab](#).

Action Plan Requirements

If test results reveal elevated lead levels above 5 parts per billion (ppb) at any outlet used for drinking or cooking, an action plan must be developed. If your school has an existing action plan, you have the option of updating the existing plan to meet the following requirements instead of creating a new one.

Per [RCW 28A.210.410](#), a school's action plan must meet the following requirements:

- The action plan shall be developed in consultation with DOH or your local health jurisdiction and in accordance with [DOH's technical guidance](#).
- Consult with the Office of the Superintendent of Public Instruction (OSPI) when seeking funding for remediation activities. The OSPI [Lead in Water Remediation Grant](#) is a potential source of funding.
- Before the action plan is officially adopted, it must be shared publicly with opportunity for public comment.
- For testing that occurred after July 25, 2021, the deadline for adopting the action plan is six months after receiving elevated lead test results.
- The action plan must include:
 - 1) **Mitigation measures** implemented since receiving elevated lead test results.
 - 2) A schedule of **remediation activities** that adhere to the [technical guidance](#). The schedule may be based on the availability of state or federal funding for remediation activities.
 - 3) A plan for **post-remediation sampling and testing** to confirm remediation activities have reduced lead concentrations at drinking water outlets to 5 or fewer ppb.

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

Action Plan

Mitigation Measures

Mitigation measures are immediate (temporary or permanent) actions, such as shutting off an outlet or marking as “hand wash only,” to stop access to drinking water with elevated lead concentrations. Outlets with lead concentrations exceeding 15 ppb must be shut off immediately upon receiving test results in accordance with the [technical guidance](#).

Balboa has identified 11 drinking water outlets with elevated lead levels requiring mitigation.

Mitigation measures have been implemented Temporary

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Mitigation Measure (Indicate temporary or permanent)	Date Implemented
1)	4/18/2024	37810	Balboa Main	Pot Filler	35	Shut off <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	5/11/2024
2)	4/18/2024	37811	Balboa Main	Sink	19	Shut off <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	5/11/2024
3)	4/18/2024	37810	Balboa Main	Sink	14	Hand Washing Only <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	5/14/2024
4)	4/18/2024	37811	Balboa Main	Sink	10	Hand Washing Only <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	5/14/2024
5)	4/18/2024	37815	Balboa B-101	Sink	10	Hand Washing only Temp	5/14/2024
6)	4/18/2024	37860	Balboa Main	Sink	9	Hand Washing Only <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	5/14/2024
7)	4/18/2024	37864	Balboa Main	Sink	9	Hand Washing Only <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	5/14/2024

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

8)	4/18/20 24	37861	Balboa Main	Sink	8	Hand Washing Only <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	5/14/2024
9)	4/18/20 24	37861	Balboa Main	Sink	8	Hand Washing Only <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	5/14/2024
10)	4/18/20 24	37815	Balboa Main	Sink	6	Hand Washing Only <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	5/14/2024
11)	4/18/20 24	37864	Balboa D-103	Sink	6	Hand Washing Only <input checked="" type="checkbox"/> temporary <input type="checkbox"/> permanent	5/14/2024

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

Remediation Schedule

Remediation activities are short-term or permanent control measures to reduce lead concentrations in drinking water to 5 ppb or less. Per RCW 28A.210.410, outlets that have elevated lead levels (above 5 ppb) must be identified, remediated (if not permanently mitigated), and retested. Refer to the [technical guidance](#) for remediation options.

Spokane Public Schools has identified 11 drinking water outlets with elevated lead levels requiring remediation. (Outlets listed in the previous table with **temporary** mitigation measures are repeated in the table below.)

Remediation activities have been or will be implemented as follows:

	Sample Collection Date	Sample ID	School Name Building Name	Fixture Information	Lead Test Result (ppb)	Remediation Activity	Planned or Completed Implementation Date
1)	4/18/2024	37810	Balboa Main	Tap	35	Change out Faucet	ASAP
2)	4/18/2024	37811	Balboa Main	Tap	19	Change out Faucet	ASAP
3)	4/18/2024	37810	Balboa Main	Tap	14	Change out Faucet	ASAP
4)	4/18/2024	37811	Balboa Main	Tap	10	Change out Faucet	ASAP
5)	4/18/2024	37815	Balboa B-101	Tap	10	Change out Faucet	ASAP
6)	4/18/2024	37860	Balboa Main	Tap	9	Change out Faucet	ASAP
7)	4/18/2024	37864	Balboa Main	Tap	9	Change out Faucet	ASAP
8)	4/18/2024	37861	Balboa Main	Tap	8	Change out Faucet	ASAP

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]

9)	4/18/20 24	37861	Balboa Main	Tap	8	Change out Faucet	ASAP
10)	4/18/20 24	37815	Balboa Main	Tap	6	Change out Faucet	ASAP
11)	4/18/20 24	37864	Balboa D-103	Tap	6	Change out Faucet	ASAP

Contact Information

For more information related to this action plan.

Spokane Public Schools Health Services

Email: rebeccado@spokaneschools.org

Phone: 509-354-7771

**Double click in this area to access footer, then: [Click here to enter school or district name. This should match document title.]