

Lead in School Drinking Water Report

Stevens Elementary School



Date(s) collected: 2024-04-26

Date(s) analyzed: 2024-05-20

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
391650	Main Building - 2108	Fountain/Tap Combo	Rm105	1 of 1	Tap	left	6
391138	Main Building - 2108	Fountain/Tap Combo	Rm133	1 of 1	Water Fountain	right	4
391143	Main Building - 2108	Fountain/Tap Combo	Rm135	1 of 1	Water Fountain	right	3
391147	Main Building - 2108	Fountain/Tap Combo	Rm113	1 of 1	Water Fountain	right	3
391149	Main Building - 2108	Fountain/Tap Combo	Rm109	1 of 1	Water Fountain	right	3
391659	Main Building	Fountain - Multi-Level	2nd Floor Hallway	2 of 2	Water Fountain	right	3

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	- 2108						
391137	Main Building - 2108	Fountain/Tap Combo	Rm137	1 of 1	Water Fountain	right	2
391153	Main Building - 2108	Fountain/Tap Combo	Rm101	1 of 1	Water Fountain	right	2
391158	Main Building - 2108	Fountain/Tap Combo	Rm211	1 of 1	Tap	left	2
391639	Main Building - 2108	Fountain/Tap Combo	Rm127	1 of 1	Water Fountain	right	2
391658	Main Building - 2108	Fountain/Tap Combo	Rm211	1 of 1	Water Fountain	right	2
391662	Main Building - 2108	Fountain/Tap Combo	Rm205	1 of 1	Water Fountain	right	2
391663	Main Building - 2108	Fountain/Tap Combo	Rm203	1 of 1	Water Fountain	right	2
391144	Main Building - 2108	Fountain/Tap Combo	Rm119	1 of 1	Water Fountain	right	1
391145	Main Building - 2108	Fountain/Tap Combo	Rm117	1 of 1	Water Fountain	right	1
391146	Main Building - 2108	Fountain/Tap Combo	Rm115	1 of 1	Water Fountain	center	1
391148	Main Building - 2108	Fountain/Tap Combo	Rm111	1 of 1	Water Fountain	right	1
391150	Main Building - 2108	Fountain/Tap Combo	Rm107	1 of 1	Water Fountain	right	1
391151	Main	Fountain/Tap	Rm105	1 of 1	Water	right	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building - 2108	Combo			Fountain		
391162	Main Building - 2108	Fountain/Tap Combo	Rm205	1 of 1	Tap	left	1
391634	Main Building - 2108	Sink - Multi-Compartment	Kitchen	Produce sink 1 of 1	Tap	center	1
391654	Main Building - 2108	Sink	Music Room	1 of 1	Tap	center	1
391657	Main Building - 2108	Fountain/Tap Combo	Rm215	1 of 1	Water Fountain	right	1
391134	Main Building - 2108	Sink - Multi-Compartment	Kitchen	Produce sink 1 of 1	Tap	center	<1
391135	Main Building - 2108	Fountain	Gym	1 of 1	Water Fountain	center	<1
391136	Main Building - 2108	Fountain with Bottle Filler	Cafeteria Hallway	1 of 1	Water Bottle Filler	center	<1
391139	Main Building - 2108	Fountain/Tap Combo	Rm127	1 of 1	Tap	left	<1
391140	Main Building - 2108	Fountain	Hallway Across Rm123	1 of 1	Water Fountain	center	<1
391141	Main Building - 2108	Fountain/Tap Combo	Rm123	1 of 1	Water Fountain	right	<1
391142	Main Building - 2108	Fountain/Tap Combo	Rm121	1 of 1	Water Fountain	right	<1
391152	Main Building - 2108	Fountain/Tap Combo	Rm103	1 of 1	Water Fountain	right	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
391154	Main Building - 2108	Fountain	Hallway Across Health Room	1 of 1	Water Fountain	center	<1
391155	Main Building - 2108	Fountain/Tap Combo	Rm219	1 of 1	Tap	left	<1
391156	Main Building - 2108	Fountain/Tap Combo	Rm217	1 of 1	Tap	left	<1
391157	Main Building - 2108	Fountain/Tap Combo	Rm215	1 of 1	Tap	left	<1
391159	Main Building - 2108	Fountain - Multi-Level	2nd Floor Hallway	1 of 2	Water Fountain	left	<1
391160	Main Building - 2108	Fountain/Tap Combo	Rm209	1 of 1	Tap	left	<1
391161	Main Building - 2108	Fountain/Tap Combo	Rm207	1 of 1	Tap	left	<1
391163	Main Building - 2108	Fountain/Tap Combo	Rm203	1 of 1	Tap	left	<1
391164	Main Building - 2108	Fountain/Tap Combo	Rm201	1 of 1	Tap	left	<1
391635	Main Building - 2108	Fountain with Bottle Filler	Cafeteria Hallway	1 of 1	Water Fountain	center	<1
391636	Main Building - 2108	Fountain/Tap Combo	Rm137	1 of 1	Tap	left	<1
391637	Main Building - 2108	Fountain/Tap Combo	Rm133	1 of 1	Tap	left	<1
391638	Main	Fountain/Tap	Rm129	1 of 1	Tap	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
	Building - 2108	Combo		fountain turned off			
391640	Main Building - 2108	Fountain/Tap Combo	Rm123	1 of 1	Tap	left	<1
391641	Main Building - 2108	Fountain/Tap Combo	Rm121	1 of 1	Tap	left	<1
391642	Main Building - 2108	Fountain/Tap Combo	Rm135	1 of 1	Tap	left	<1
391643	Main Building - 2108	Fountain/Tap Combo	Rm119	1 of 1	Tap	left	<1
391644	Main Building - 2108	Fountain/Tap Combo	Rm117	1 of 1	Tap	left	<1
391645	Main Building - 2108	Fountain/Tap Combo	Rm115	1 of 1	Tap	left	<1
391646	Main Building - 2108	Fountain/Tap Combo	Rm113	1 of 1	Tap	left	<1
391647	Main Building - 2108	Fountain/Tap Combo	Rm111	1 of 1	Tap	left	<1
391648	Main Building - 2108	Fountain/Tap Combo	Rm109	1 of 1	Tap	left	<1
391649	Portable A	Fountain/Tap Combo	Rm107	1 of 1	Tap	left	<1
391651	Main Building - 2108	Fountain/Tap Combo	Rm103	1 of 1	Tap	left	<1
391652	Main Building - 2108	Fountain/Tap Combo	Rm101	1 of 1	Tap	left	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
391653	Main Building - 2108	Sink	Health Room	1 of 1	Tap	center	<1
391655	Main Building - 2108	Fountain/Tap Combo	Rm219	1 of 1	Water Fountain	right	<1
391656	Main Building - 2108	Fountain/Tap Combo	Rm217	1 of 1	Water Fountain	right	<1
391660	Main Building - 2108	Fountain/Tap Combo	Rm209	1 of 1	Water Fountain	right	<1
391661	Main Building - 2108	Fountain/Tap Combo	Rm207	1 of 1	Water Fountain	right	<1
391664	Main Building - 2108	Fountain/Tap Combo	Rm201	1 of 1	Water Fountain	right	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: leadfreekids@doh.wa.gov